

## Features for guests with walking difficulties and guests using temporarily a wheelchair or walking aid

### I. Hotel

#### 1. Access to hotel

1.1	Access with no steps or maximum 1 step <u>alternatively:</u> Access via ramp angled at $\leq 6\%$ or by lift	<input checked="" type="checkbox"/>  <input type="checkbox"/>
1.2	No revolving doors as access <u>alternatively:</u> Additional entrance door (with no steps or maximum 1 step, easily usable during opening hours)	<input type="checkbox"/>  <input checked="" type="checkbox"/>
1.3	Width of hotel entrance door minimum 80 cm	<input type="checkbox"/>

#### 2. Reception

2	Reception counter or desk partially lowered to a height of 85 cm <u>alternatively:</u> Other means of communicating from sitting position	<input type="checkbox"/>  <input checked="" type="checkbox"/>
---	---	---

#### 3. Access to the rooms and eating areas

3.1	Access to the rooms with no steps or maximum 1 step <u>alternatively:</u> Access via ramp angled at $\leq 6\%$ or by lift	<input checked="" type="checkbox"/>  <input type="checkbox"/>
3.2	Width of doors into and within the rooms minimum 80 cm	<input checked="" type="checkbox"/>
3.3	Access to eating areas with no steps or maximum 1 step <u>alternatively:</u> Access via ramp angled at $\leq 6\%$ or by lift	<input checked="" type="checkbox"/>  <input type="checkbox"/>
3.4	Width of doors into eating areas minimum 80 cm	<input checked="" type="checkbox"/>

#### 4. Corridors

4.1	Minimum width of corridors leading to lifts, 120 cm	x
4.2	Minimum width of corridors leading to rooms, 120 cm	x
4.3	Minimum width of corridors leading to other facilities (e.g. eating areas), 120 cm	x

#### 5. Lift

5.1	Access to lift with no steps or maximum 1 step <u>alternatively:</u> Access via ramp angled at $\leq 6\%$	<input checked="" type="checkbox"/> <input type="checkbox"/>
5.2	Width of lift door minimum 90 cm	x
5.3	Depth of lift chamber minimum 140 cm	x
5.4	Width of lift chamber minimum 110 cm	x
5.5	Horizontal positioning of lift control panel at minimum height of 85 cm <sup>1</sup> <u>alternatively:</u> Vertical positioning at a height of minimum 85 cm and maximum 140 cm	<input checked="" type="checkbox"/> <input type="checkbox"/>
5.6	Space in front of lift minimum 120 cm x 120 cm	x

#### 6. Rooms

6.1	Space <sup>2</sup> in front of the internal bathroom minimum 120 cm x 120 cm	x
6.2	Space between the passage and the side of the bed minimum 120 cm x 120 cm	x
6.3	Minimum width of space beside the bed 120 cm	x
6.4	Minimum space next to controls and items of furniture (e.g. light switch, wardrobe) 90 cm	x
6.5	Minimum space of all passages within the room 80 cm	x

## 7. Bathrooms

7.1	Access to the internal bathrooms with no steps or over a sill of maximum 2 cm	x
7.2	Door width minimum 80 cm	x
7.3	Bathroom door does not open inwards	x
	<u>alternatively:</u> Bathroom door opens inwards but this does not impinge on the spaces defined below	<input type="checkbox"/>
7.4	Space <sup>2</sup> in front of basin minimum 120 cm x 120 cm	x
7.5	Legroom underneath basin <sup>3</sup>	x
7.6	Mirror above basin visible from sitting or standing	x
7.7	Space <sup>2</sup> in front of WC minimum 120 cm x 120 cm	x
7.8	Space <sup>2</sup> to the right <u>or</u> left of WC with a minimum width of 95 cm and a minimum depth of 70 cm	x
7.9	Right <u>and</u> left grab handles next to WC at a height of 85 cm (upper edge)	x
7.10	Projection of grab handles 15 cm above the front edge of WC	x
7.11	Distance between grab handles of 70 cm	x
7.12	Grab handle next to WC that can be folded upwards and locked in this position of a minimum width of 95 cm and a minimum depth of 70 cm	x
7.13	Seat height of WC (upper edge of toilet seat) 48 cm	x
7.14	Wheelchair-accessible shower with no step	x
7.15	Space <sup>2</sup> inside shower of minimum 120 cm x 120 cm	<input type="checkbox"/>
7.16	Grab handles inside shower starting at a height of 85 cm from the floor	x
7.17	Shower stool or seat	x

## 8. Car park

8.1	Parking spaces with a minimum width of 350 cm near the hotel entrance	x
8.2	Designation of this parking space as a disabled parking space	x

## 9. Number of rooms

9	At least one double or twin room complies with these criteria Total number of appropriate single rooms: ____ Double or twin room: <u>1</u>	x
---	--	---

## II. Catering operation

### 10. Access, doors, corridors

10.1	Access with no steps or maximum 1 step <u>alternatively:</u> Access via ramp angled at $\leq 6\%$ or by lift	x <input type="checkbox"/>
10.2	No revolving doors as access <u>alternatively:</u> Additional entrance door (no steps or maximum 1 step, easily usable during opening hours)	x <input type="checkbox"/>
10.3	Width of entrance door minimum 80 cm	x
10.4	Width of other available doors minimum 80 cm	x
10.5	Minimum width of halls and corridors 120 cm	x

### 11. Lift

11.1	Access to lift with no steps or maximum 1 step <u>alternatively:</u> Access via ramp angled at $\leq 6\%$	x <input type="checkbox"/>
11.2	Width of lift door minimum 90 cm	x
11.3	Depth of lift chamber minimum 140 cm	x
11.4	Width of lift chamber minimum 110 cm	x
11.5	Horizontal positioning of lift control panel at minimum height of 85 cm <sup>1</sup> <u>alternatively:</u> Vertical positioning at a height of minimum 85 cm to maximum 140 cm	x <input type="checkbox"/>
11.6	Space in front of lift minimum 120 cm x 120 cm	x

## 12. Tables

12	Minimum one table with a maximum height of 85 cm and appropriate seating available Total number of appropriate tables: ___ Total number of appropriate seats: ___	x
----	---	---

## 13. Guest toilets

13.1	Access with no steps to at least one WC in the building <u>alternatively:</u> Access via ramp angled at $\leq 6\%$ or by lift	<input checked="" type="checkbox"/> <input type="checkbox"/>
13.2	Door width minimum 80 cm	x
13.3	Bathroom door does not open inwards <u>alternatively:</u> Bathroom door opens inwards but this does not impinge on the spaces defined below	<input checked="" type="checkbox"/> <input type="checkbox"/>
13.4	Space <sup>2</sup> in front of basin minimum 120 cm x 120 cm	x
13.5	Legroom underneath basin <sup>3</sup>	x
13.6	Mirror above basin visible from sitting or standing position	x
13.7	Space <sup>2</sup> in front of WC minimum 120 cm x 120 cm	x
13.8	Space <sup>2</sup> right <u>or</u> left of WC with a minimum width of 95 cm and a minimum depth of 70 cm	x
13.9	Right <u>and</u> left grab handles next to WC at a height of 85 cm (upper edge)	x
13.10	Projection of grab handles 15 cm above the front edge of WC	x
13.11	Distance between grab handles of 70 cm	x
13.12	Grab handle next to WC that can be folded upwards and locked in this position of a minimum width of 95 cm and a minimum depth of 70 cm	x
13.13	Seat height of WC (upper edge of toilet seat) 48 cm	x

## 14. Guest parking spaces

14.1	Minimum one parking space with a minimum width of 350 cm near the entrance	x
14.2	Designation of this parking space as a disabled parking space	x

- 
- <sup>1</sup> The height of all control elements is measured from the mid-line (centre-to-centre distance) of the lowest (for minimum height) or highest (for maximum height) control element.
  - <sup>2</sup> Spaces can overlap; however, their function must not be restricted in any way e.g. through items or furniture or doors.
  - <sup>3</sup> Legroom is available when the use of the basin is not restricted by cover panels, cupboard or similar.